

SPECIFICATIONS

10,000 Gallon Dual Wall Saddle (Gasonline)

10,000 Gallon Dual Wall Saddle (Diesel)

Emergency Vent (4)

Three inch remote overspill/overflow package (2)

Aluminum Drop Tubes, 2 inch by 12 feet (2)

Paint (as necessary)

Rung Ladder (welded to each tank) (2) (specify if price is per rung or per complete ladder)

Leak Gauge (2)

Two inch #749 eight ounce pressure vacuum vent (2)

Two inch by 48 inch TBE nipple (2)

Four inch steel plug (2)

Two inch clock gauge alarm with drop tube float

Turn key pump pack, 115 volt, 35 GPM (pump, hose, nozzle, filter) (2)

Remote dispenser meter (2)

96 Inch tank pump piping, two inch line including ball valve/anti-syphoning valve (2)

24 inch square pump platform (2)

Include specification for tank site (concrete pad size, pier size, number of piers, etc...) Location will be prepared by the City and ready for tank installation.

All items installed

Bids must be valid for 10 days past the bid opening date as stated.
